

Memo

To: Tennessee Valley Authority
Chattanooga, TN

From: Matthew Dagon, LPG
Indianapolis, IN

Project/File: Updated GWPS and SSLs at the
Kingston Fossil Plant Sluice Trench
Vacatur CCR Unit

Date: December 19, 2024

Reference: End of Year Update on Statistically Significant Levels (SSLs) (40 CFR § 257.95(g)) - CCR Rule Groundwater Monitoring - Kingston Fossil Plant, Sluice Trench Vacatur CCR Unit

In accordance with the federal regulations for management of coal combustion residuals (CCR Rule; 40 Code of Federal Regulations [CFR] Part 257, Subpart D), the Tennessee Valley Authority (TVA) is currently conducting Assessment Monitoring at the Sluice Trench and Area East of Sluice Trench (Sluice Trench) Vacatur CCR unit at its Kingston Fossil Plant (KIF) in Kingston, Tennessee. The Sluice Trench consists of one CCR surface impoundment subject to the CCR Rule with a single-unit groundwater monitoring system.

As required by the CCR Rule, the owner or operator of a CCR unit shall establish groundwater protection standards (GWPS) for Appendix IV parameters detected during Assessment Monitoring and determine if one or more Appendix IV parameters are detected at statistically significant levels (SSLs) above their GWPS. GWPS for all Appendix IV parameters were originally established and documented in a notice dated April 14, 2020, as required by 40 CFR § 257.95(d)(2) and are provided on Table 1.

As part of ongoing Assessment Monitoring, the second semiannual assessment monitoring event for 2024 occurred July 30 through August 5, 2024, with the additional “resample” event occurring September 10-19, 2024. This technical memorandum presents GWPS and lower confidence bands (LCBs) that have been updated with data collected during the second semiannual monitoring event and resample event for 2024, as well as any identified SSLs after incorporating the additional data collected in 2024. The identification of SSLs was performed as a two-step process:

1. Historical sampling results (January 2019 through September 2024) for Appendix IV parameters from each downgradient well were compared directly to the updated GWPS. If all sample concentrations were below the updated GWPS, no SSLs over the GWPS were identified.
2. Where the direct comparison indicated a concentration above the GWPS, further statistical analysis was performed to identify levels statistically greater than the GWPS, using procedures recommended in the United States Environmental Protection Agency (USEPA) Unified Guidance for Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities (EPA 530/R-09-007, March 2009). Comparisons were made against a fixed GWPS via LCBs. For each situation where a parameter concentration was greater than the GWPS in step one, the 99% LCB of the fitted line in that monitoring well was calculated using CCR Rule monitoring data collected from January 2019 through September 2024. As recommended in the Unified Guidance, where the 99% LCB exceeds the GWPS at the last sampling event an SSL was identified for the parameter/monitoring well pair.

Based on the statistical analysis performed in 2024, there continues to be SSLs above the GWPS for cobalt in monitoring wells AD-2 and KIF-105. TVA will continue to conduct groundwater monitoring and reporting pursuant to 40 CFR § 257.95.

Reference: End of Year Update on Statistically Significant Levels (SSLs) (40 CFR § 257.95(g)) - CCR Rule Groundwater Monitoring - Kingston Fossil Plant, Sluice Trench Vacatur CCR Unit

TABLE 1: Statistically Significant Levels Above GWPS - KIF Sluice Trench Vacatur CCR Unit

Appendix IV Parameter	GWPS (a)	Updated GWPS (b)	Downgradient wells with analytical results above GWPS (c)	Updated LCBs (d)	SSL LCB > GWPS (e)
Antimony (µg/L)	6	6	None	NA	NA
Arsenic (µg/L)	10	10	None	NA	NA
Barium (µg/L)	2,000	2,000	None	NA	NA
Beryllium (µg/L)	4	4	None	NA	NA
Cadmium (µg/L)	5	5	None	NA	NA
Chromium (µg/L)	100	100	None	NA	NA
Cobalt (µg/L)	6	6	AD-2	14.6	Yes
			AD-3	2.6	No
			KIF-105	26.7	Yes
			KIF-109	0.0 ^(f)	No
Fluoride (mg/L)	4	4	None	NA	NA
Lead (µg/L)	15	15	None	NA	NA
Lithium (µg/L)	40	40	None	NA	NA
Mercury (µg/L)	2	2	None	NA	NA
Molybdenum (µg/L)	100	100	None	NA	NA
Radium-226+228 (pCi/L)	5	5	None	NA	NA
Selenium (µg/L)	50	50	None	NA	NA
Thallium (µg/L)	2	2	None	NA	NA

NA – Not applicable

- (a) GWPS documented in notice dated April 14, 2020 [reported in micrograms per liter (µg/L) except fluoride (mg/L) and radium 226+228 (pCi/L)]
- (b) GWPS updated as of November 22, 2024, with results from two additional sample events collected on July 30 through August 5, 2024, and September 10-19, 2024 [reported in µg/L except fluoride (mg/L) and radium 226+228 (pCi/L)]
- (c) Downgradient wells with analytical results above GWPS January 2019 through September 2024 (per 40 CFR § 257.95(b) and (d))
- (d) Most recent value of 99% lower confidence band (LCB) on the mean of Appendix IV groundwater sampling events between January 2019 and September 2024. Upper confidence band (UCB) not shown as it is greater than LCB.
- (e) SSL: “statistically significant level over GWPS” occurs when the updated LCB value at the last sampling event exceeds the updated GWPS
- (f) Negative lower confidence bands were reported as 0.0 µg/L