

TECHNICAL MEMORANDUM

TO: Tennessee Valley Authority
Paradise Fossil Plant

FROM: Jeffrey D. Frazier
WSP Golder, Chattanooga TN

FILE: Updated GWPS and SSLs at the Paradise
Fossil Plant Slag Ponds Area CCR Units

DATE: December 22, 2022

**REFERENCE: END OF YEAR UPDATE ON STATISTICALLY SIGNIFICANT LEVELS (SSLs) – CCR
RULE GROUNDWATER MONITORING – PARADISE FOSSIL PLANT, SLAG PONDS
AREA CCR UNITS**

In accordance with the federal regulations for management of coal combustion residuals (CCR Rule; 40 CFR Part 257, Subpart D), the Tennessee Valley Authority (TVA) is currently conducting Assessment Monitoring for the Slag Ponds Area CCR Units at its Paradise Fossil Plant (SHF) in Drakesboro, Kentucky.

As required by the CCR Rule, the owner or operator of a CCR unit shall establish groundwater protection standards (GWPS) for Appendix IV parameters detected during Assessment Monitoring and determine if one or more Appendix IV parameters are detected at statistically significant levels (SSLs) above their GWPS. GWPS for all Appendix IV parameters were originally established and documented in a notice dated October 15, 2018, as required by 40 CFR § 257.95(d)(2) and are provided on Table 1.

As part of ongoing Assessment Monitoring, the second semiannual assessment monitoring event for 2022 occurred August 9-17, 2022, with the additional “resample” event occurring September 20-27, 2022. This technical memorandum presents GWPS and lower confidence bands (LCBs) that have been updated with data collected during the second semiannual monitoring event and resample event for 2022, as well as any identified SSLs after incorporating the additional data collected in 2022¹. The updated GWPS has been calculated using data collected at background wells (95-48A, PAF-108, and PAF-109) from November 2016 through September 2022. To statistically evaluate the Appendix IV constituents, concentration data are compared to the GWPS through the use of confidence bands. In assessment monitoring, a well is determined to be out of compliance and has an SSL when the lower confidence band (LCB), and thus the entire confidence interval, exceeds the GWPS, as discussed in *Unified Guidance*. If the compliance data at a given well-constituent pair show evidence of a significant trend, a linear regression line will be fit to the data and a confidence band with a 99% confidence level will be constructed around the trend line. To evaluate compliance with regulatory standards, the lower edge of the confidence band at the most recent sampling event will be compared to the GWPS. If the lower edge exceeds the GWPS at that point in time (thus guaranteeing the entire vertical cross-section of the band also exceeds the GWPS at that point), an SSL will be recorded. If the lower edge of the confidence band does not exceed the GWPS, no SSL has occurred. As new sampling events are collected, the trend estimate will be updated along with the confidence band.

¹ Previously, TVA has provided notification of SSLs for the second semiannual assessment monitoring sampling in the Annual Groundwater Monitoring and Corrective Action Reports.

Based on the statistical analysis performed in 2022, there continues to be an SSL above the GWPS for arsenic in wells PAF-112 and PAF-113. TVA will continue to conduct groundwater monitoring and reporting pursuant to 40 CFR § 257.95.

TABLE 1: Statistically Significant Levels Above GWPS – PAF Slag Ponds Area

Appendix IV Parameter	GWPS (a)	Updated GWPS (b)	Downgradient wells with analytical results above GWPS (c)	Updated LCBs (d)	SSL LCB > GWPS (e)
Antimony (µg/L)	6	6	None	NA	NA
Arsenic (µg/L)	13.4	10.2	PAF-112 PAF-113	20.95 72.56	Yes Yes
Barium (µg/L)	2,000	2,000	None	NA	NA
Beryllium (µg/L)	4	4	None	NA	NA
Cadmium (µg/L)	5	5	None	NA	NA
Chromium (µg/L)	100	100	None	NA	NA
Cobalt (µg/L)	89.7	89.7	None	NA	NA
Fluoride (µg/L)	4,000	4,000	None	NA	NA
Lead (µg/L)	15	15	None	NA	NA
Lithium (µg/L)	170	179	95-47C	152.67	No
Mercury (µg/L)	2	2	None	NA	NA
Molybdenum (µg/L)	100	100	None	NA	NA
Radium-226+228 (pCi/L)	5	5	None	NA	NA
Selenium (µg/L)	50	50	None	NA	NA
Thallium (µg/L)	2	2	None	NA	NA

NA – Not applicable

- (a) GWPS documented in notice dated October 15, 2018 [reported in milligrams per liter (µg/L)]
- (b) GWPS updated as of November 29, 2022, with results from two additional sampling events collected on August 9-17, 2022, and September 20-27, 2022 [reported in µg/L]
- (c) Downgradient wells with analytical results above GWPS November 2016 through September 2022 (per 40 CFR § 257.95(b) and (d))
- (d) Most recent value of 99% lower confidence band (LCB) on the mean of Appendix IV groundwater sampling events between November 2016 and September 2022. Upper confidence band (UCB) not shown as it is greater than LCB.
- (e) SSL: “statistically significant level” over GWPS occurs when the updated LCB value at the last sampling event exceeds the updated GWPS